

CERTIFICATE

on the antibacterial properties of

Ventilation pipe antibacterial

of the company

Maincor Rohrsysteme GmbH & Co. KG
Silbersteinstraße 14, 97424 Schweinfurt, Germany

has been successfully tested versus

Staphylococcus aureus DSM 799 ATCC 6538
Escherichia coli DSM 1576 ATCC8739

as **antibacterial**
(> 99.9% germ reduction)

according to ISO 22196 (modified)

For details, see Test Reports No. 3950.1 and 3950.2 (2021)

The bearer of this certificate is entitled to affix the following seal to parts or surfaces made from the tested material



Nuremberg, Germany, 29th July 2021



Managing Director



Laboratory Director